



SINCE 1844

ROCKAWAY TOWNSHIP

65 MOUNT HOPE ROAD, ROCKAWAY, NEW JERSEY 07866

DEPARTMENT OF FIRE
Fire Prevention Bureau

RECALL NOTICE

Description:

This recall involves Kidde TruSense Smoke Alarms and Combination Smoke/Carbon Monoxide Alarms.

The recalled units are Kidde Model Series 2040, 2050, 2060 and 2070 Smoke and Combination Smoke/Carbon Monoxide alarms. Only alarms with the TruSense logo or "AMBER=FAULT" printed on the front of the alarm are included in this recall. The model number is printed on the back of the alarm.

Model	Alarm Type
2040-DSR	Smoke
2050-DS10	Smoke
2060-ASR	Smoke
2070-VDSCR	Combination Smoke/Carbon Monoxide
2070-VASCR	Combination Smoke/Carbon Monoxide
2070-VDSR	Smoke
2070-VASR	Smoke

Remedy:

Consumers should immediately contact Kidde for a free replacement alarm. Consumers should keep using the recalled alarms until they install replacement alarms.

Sold At:

Walmart, Home Depot, Menards and other department, home and hardware stores and electrical distributors nationwide, and online at Amazon.com, ShopKidde.com and other online retailers from May 2019 through September 2020 for between \$10 and \$70.

Importer(s):

Walter Kidde Portable Equipment Company Inc., of Mebane, N.C.

Recall number:

21-130

For more information, please visit:

<https://www.cpsc.gov/Recalls/2021/Kidde-Recalls-TruSense-Smoke-and-Combination-Smoke-Carbon-Monoxide-Alarms-Due-to-Risk-of-Failure-to-Alert-Consumers-to-a-Fire>