

PWS ID# 143602
CLASSIFICATION: T-2

MAIL CODE - 401-404
NORTH BUREAU OF SAFE DRINKING WATER
PO BOX 420
401 E STATE ST., 4TH FLOOR
TRENTON, NJ 08625-0420

ROCKAWAY TOWNSHIP MUNICIPAL UTILITY
65 MOUNT HOPE ROAD
ROCKAWAY, N.J. 07866-1888
1-973-983-2826

MONTHLY OPERATING REPORT
OF WATER TREATMENT PLANTS

YEAR: 2022
MONTH: January

DAY	PUMPAGE M3/D														MT.	Calcium Hypochlorite Tablets			HYPO USED	FREE CHL RESIDUALS			PO-4 RESIDUAL			BACTERIOLOGICALS SYSTEM RESULTS
	WELL 6	WELL 7	WELL 7A	WELL 8	WELL 11	WELL 12	WELL 13	WELL 14	PLESKANT	GREENBOND PLANT IN LBS.	HEWLETT PACKARD PLANT IN INCHES	FOX HILL PLANT IN INCHES	WELL 8/7/7A	WELL 8		WELL 11/12/13/14	WELL 8/7/7A	WELL 11/12/13/14		WELL 8/7/7A	WELL 11/12/13/14					
1	0.284	0.271	0.000	0.280	0.041	0.031	0.020	0.021	0.088	8.4	2.2	2.0	0.78	0.72	0.71	0.88	0.59									
2	0.280	0.274	0.000	0.282	0.048	0.032	0.027	0.024	0.088	7.8	1.9	2.0	0.26	0.72	0.87	1.07	0.59									
3	0.219	0.609	0.000	0.248	0.043	0.027	0.009	0.024	0.088	7.5	1.7	1.9	0.65	0.68	0.80	0.8	1.31									
4	0.230	0.720	0.000	0.318	0.047	0.032	0.076	0.029	0.088	8.6	2.0	1.8	0.6	0.33	0.78	0.28	1.16									
5	0.235	0.723	0.000	0.311	0.052	0.036	0.076	0.029	0.088	8.9	2.0	1.9	0.22	0.48	0.88	1.13	0.98			7						
6	0.248	0.780	0.000	0.347	0.041	0.025	0.088	0.022	0.054	8.8	2.0	0.9	0.5	0.33	0.33	0.63	0.87									
7	0.229	0.712	0.000	0.290	0.058	0.029	0.088	0.028	0.000	8.2	1.9	1.5	0.55	0.34	0.37	0.63	0.77									
8	0.280	0.793	0.000	0.293	0.064	0.029	0.088	0.028	0.106	8.2	1.9	1.5	0.46	0.12	0.32	0.3	0.55									
9	0.228	0.719	0.000	0.282	0.047	0.029	0.088	0.028	0.087	7.8	2.1	2.0	0.26	0.26	0.26	0.26	0.52									
10	0.246	0.734	0.000	0.289	0.046	0.030	0.075	0.025	0.087	6.5	1.8	1.4	0.29	0.26	0.26	0.26	0.52			7						
11	0.239	0.757	0.000	0.308	0.037	0.022	0.063	0.020	0.081	4.1	1.7	1.6	0.37	0.26	0.26	0.26	0.52									
12	0.227	0.882	0.000	0.381	0.034	0.022	0.052	0.020	0.081	4.1	1.7	2.2	0.37	0.26	0.26	0.26	0.52									
13	0.183	0.692	0.000	0.288	0.036	0.022	0.052	0.020	0.029	4.1	2.5	2.2	0.37	0.43	0.26	0.26	0.52									
14	0.183	0.819	0.000	0.356	0.034	0.022	0.057	0.022	0.029	7.4	2.3	2.2	0.75	0.82	0.26	0.26	0.52									
15	0.183	0.674	0.000	0.389	0.042	0.024	0.089	0.022	0.070	5.7	1.9	0.4	0.74	0.82	0.26	0.26	0.52									
16	0.183	0.801	0.000	0.409	0.046	0.024	0.074	0.022	0.063	6	0.8	1.3	0.58	0.57	0.26	0.26	0.52									
17	0.172	0.784	0.000	0.256	0.040	0.025	0.065	0.022	0.116	5.4	2.6	3.8	0.98	0.19	0.45	0.45	0.78									
18	0.158	0.690	0.000	0.365	0.041	0.024	0.077	0.024	0.116	5.5	2.1	0.6	0.56	0.50	0.22	0.22	0.48			7						
19	0.160	0.690	0.000	0.349	0.040	0.024	0.077	0.024	0.116	4.5	0.8	1.8	0.92	0.19	0.41	0.41	0.48									
20	0.167	0.739	0.000	0.395	0.041	0.025	0.074	0.022	0.080	6.4	1.4	1.0	1.04	0.19	0.31	0.31	0.24									
21	0.174	0.787	0.000	0.345	0.031	0.018	0.049	0.015	0.077	4.5	0.8	1.0	0.92	0.19	0.41	0.41	0.48									
22	0.160	0.724	0.000	0.396	0.048	0.031	0.083	0.023	0.083	5.3	1.1	1.8	0.35	0.18	0.20	0.20	0.54									
23	0.167	0.749	0.000	0.370	0.051	0.030	0.077	0.025	0.083	6.4	1.4	1.0	1.04	0.19	0.31	0.31	0.24									
24	0.163	0.888	0.000	0.399	0.044	0.034	0.077	0.025	0.131	3.2	0.8	2.4	0.33	0.18	0.24	0.24	0.54									
25	0.150	0.678	0.000	0.389	0.044	0.034	0.077	0.025	0.131	4	0.8	1.8	0.5	0.40	0.32	0.32	0.54									
26	0.150	0.678	0.000	0.389	0.044	0.034	0.077	0.025	0.131	4.7	1.9	1.5	0.25	0.33	0.33	0.33	0.54									
27	0.168	0.883	0.000	0.290	0.000	0.000	0.000	0.000	0.088	3.3	0.31	0.6	0.31	0.41	0.19	0.19	0.88									
28	0.178	0.789	0.000	0.397	0.000	0.000	0.000	0.000	0.189	4.8	0.4	0.0	0.31	0.37	0.37	0.37	0.48									
29	0.178	0.789	0.000	0.394	0.000	0.000	0.000	0.000	0.152	3.2	0.4	0.8	0.42	0.43	0.24	0.24	0.52									
30	0.180	0.715	0.000	0.288	0.000	0.000	0.000	0.000	0.185	7.5	2.4	0.8	0.42	0.20	0.22	0.22	0.48									
31	0.183	0.731	0.000	0.320	0.000	0.000	0.000	0.000	0.143	6.3	0.8	0.8	0.38	0.37	0.35	0.35	0.44									
SUB TOTAL	8.133	23.078	0	10.183441	1.125401	0.8807	1.730	0.678	2.672218	184.1	47.9	46.3	15.89	11.80	14.03	18.37	21.8			21						
TOTAL GALLONS	46,784,461																									
AVERAGE	0.188	0.744	0.000	0.328	0.038	0.028	0.056	0.022	0.086	5.839	1.545	1.404	0.513	0.387	0.453	0.583	0.703			7.000						
Notes:																										
Test Results in PPM or MG/L																										
TEMP: F/deg																										

I HEREBY CERTIFY THE ABOVE TO BE CORRECT
Ryan Furness T-3-918603
Licensed Operator of Record

DATE 2/9/2022